


STOP CORONA

WEAR MASK

MAINTAIN SOCIAL DISTANCE



DELHI JAL BOARD: GNCTD
CENTRAL LABORATORY WTP WAZIRABAD, DELHI-54



THE REPORT PERTAINS TO THE
PARTICULAR SAMPLE ONLY

TEST REPORT

Sample ID	Ref.No. D.J.B/DTQC/Wzd./2022/Paid-51-52		
Location /Address of Sample	Manav Sthali School, R-Block New Rajender Nagar Delhi-60		
Name of Work	--		
Reference No.	MSS/NRN/10275	Ref. Letter Date	13.06.2022
Challan No.	93	Challan Date	13.06.2022
Sample Collection date	16.06.2022	Analysis date	16.06.2022
Any other Information	--	Reporting date	20.06.2022

TEST RESULTS

S.N.	Parameters	Unit	As per the IS 10500		Inlet	Outlet
			Desirable limit	Permissible limit		
1	Turbidity	NTU	1	5	1.90	1.50
2	pH Value	--	6.5-8.5	No relaxation	7.46	7.47
3	Colour	Pt-Co	5	15	Clear	Clear
4	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
5	Electrical Conductivity	µs/cm	-	-	426	421
6	Total Dissolved Solids	Mg/l	500	2000	213	210
7	Total Alkalinity as CaCO ₃	Mg/l	200	600	80	80
8	Total Hardness as CaCO ₃	Mg/l	200	600	160	152
9	Calcium as Ca	Mg/l	75	200	44	37.6
10	Magnesium as Mg	Mg/l	30	100	12	13.96
11	Ammonical-Nitrogen	Mg/l	NIL	0.5	ND	ND
12	Nitrate	Mg/l	--	45	5.30	5.32
13	Chlorides as Cl	Mg/l	250	1000	66	58
14	Fluoride as F	Mg/l	1.0	1.5	0.57	0.59
15	Sulphate as SO ₄	Mg/l	200	400	39.2	40.6
16	T. Iron	Mg/l	--	1.0	0.08	0.08
17	Residual Chlorine	Mg/l	0.2	1.0	0.50	ND
18	COLIFORM COUNT AT 37 ^o C	MPN/100 ml	Absent	--	0	0

.....End of Report.....

Remarks : On the basis of above tested parameters, above water samples conform drinking Water Specification IS-10500 & can be considered fit for drinking purpose.

ACWA

CHEMIST

CHEMIST

Analyst
Central Laboratory, W.T.P. of Delhi
Wazirabad

Principal
MANAV STHALI SCHOOL
R-Block, New Rajinder Nagar,
New Delhi - 110060



MUNICIPAL CORPORATION OF DELHI
(Office of the Deputy Health Officer)
Public Health Department: Karol Bagh Zone
Anand Parbat, New Delhi – 110005
Phone No. 011-25818502,
E-mail ID No. dhokbz@gmail.com

No. DHO/KBZ/2022/ 579

Dated: 05-08-2022

Name of School **MANAV STHALI SCHOOL, R-BLOCK, NEW RAJENDRA NAGAR, NEW DELHI- 110060.**


Shift: Timing 07:30 am to 01:40 pm

No., of Students: Boys 1370 Girls 792


No. of Staff Members Working in School Total 79

1. That the accommodation provided for in class rooms as calculated.
- Floor space in the class room is sufficient.
2. That the all rooms are well ventilated white washed and well lighted.
3. That the class rooms are kept neat and clean.
4. That the building, class rooms are in good condition.
5. That the drinking water is wholesome.
6. That the first aid box is also arranged in proper manner.
7. That the latrine arrangement is flush.
8. The no. of urinal seats for Staff 32
9. The no. of urinal seats for Boys 32
10. The no. of urinal seats for Girls 13
11. The premises found fit having no objection from Health point of view.

subject to submission of fire Safety certificate by due date on 17-12-2022


Principal

MANAV STHALI SCHOOL
R-Block, New Rajinder Nagar,
New Delhi - 110060


Deputy Health Officer
Karol Bagh Zone